

Relationship between Human Thermal Comfort and Indoor Thermal Environment Parameters in Various Climatic Regions of China

Downloaded from: https://research.chalmers.se, 2025-07-02 19:39 UTC

Citation for the original published paper (version of record):

Duanmu, L., Sun, X., Jin, Q. et al (2017). Relationship between Human Thermal Comfort and Indoor Thermal Environment Parameters in Various Climatic Regions of China. Procedia Engineering, 205: 2871-2878. http://dx.doi.org/10.1016/j.proeng.2017.09.913

N.B. When citing this work, cite the original published paper.

research.chalmers.se offers the possibility of retrieving research publications produced at Chalmers University of Technology. It covers all kind of research output: articles, dissertations, conference papers, reports etc. since 2004. research.chalmers.se is administrated and maintained by Chalmers Library



CrossMark

Available online at www.sciencedirect.com





Procedia Engineering 205 (2017) 2871-2878

www.elsevier.com/locate/procedia

10th International Symposium on Heating, Ventilation and Air Conditioning, ISHVAC2017, 19-22 October 2017, Jinan, China

Relationship between Human Thermal Comfort and Indoor Thermal Environment Parameters in Various Climatic Regions of China

Lin Duanmu^{a, *}, Xingwei Sun^a, Quan Jin^b, Zhiqiang Zhai^{a,c}

^aFirst affiliation, Dalian University of Technology, Dalian 116024, China ^bSecond affiliation, Chalmers University of Technology, Gothenburg SE-41296, Sweden ^cThird affiliation, University Colorado at Boulder, Boulder, CO, 80309-0428, USA

Abstract

Architectural design is based on the reliability and rationality of construction standards. The thermal comfort standard is a very important part of construction standards. In this study, Chinese researches about the field survey of various areas were summarized. The distribution range of thermal comfort temperature and neutral temperature were obtained by using the PMV evaluation index. The neutral temperature of different types of buildings in different seasons was summarized. Its relationship with indoor parameters was analyzed in detail. These findings provide a basis for the formulation of building specifications and architectural design in future.

© 2017 The Authors. Published by Elsevier Ltd.

Peer-review under responsibility of the scientific committee of the 10th International Symposium on Heating, Ventilation and Air Conditioning.

Keywords: The building standards, Thermal comfort, Temperature, Climatic region;

1. Introduction

The specifications of building thermal comfort include the temperature, humidity, wind speed and others, which can directly affect the thermal environment and building energy consumption. With the improvement of living standards of people, people paid more attention to the comfort of the living environment. how to make the building thermal comfort standards meet the needs of human body becomes more and more important [1].

Due to the difference of the geographical location, architectural function, living environment, personnel status, the thermal comfort specifications are different, the impact of different parameters is different ^[2]. The main purpose of

1877-7058 $\ensuremath{\mathbb{C}}$ 2017 The Authors. Published by Elsevier Ltd.

Peer-review under responsibility of the scientific committee of the 10th International Symposium on Heating, Ventilation and Air Conditioning.

^{*} Corresponding author. Tel.: 0411-84709612; fax: +86 411 84674141. *E-mail address:* duanmu@dlut.edu.cn

this paper is to give some suggestions about the thermal comfort in a more reasonable and energy efficient way without reducing the indoor comfort level.

In this paper, 71 papers about thermal comfort investigation in China in the past 21 years from 1995 to now are introduced, and the thermal comfort range and thermal neutral temperature of different climate zones and different types of buildings are systematically summarized. The relationship between the statistical results of the thermal neutral temperature and the measured temperature is analyzed in detail, which provides a reference for the future design of the building and the building specifications.

2. Methods

The climate in China is divided into severe cold areas, cold areas, hot summer and cold winter areas, hot summer and warm winter areas and warm areas, while China is divided into North and south by the Qinling and Huaihe. The research of this paper involves all seasons and different populations in china.

In order to illustrate the representativeness of the samples, the paper summarizes the geographical distribution of the literature as shown in Figure1, in which the circle represents the summer, the triangle represents the transition season, and the box represents the winter. According to Figure1, we can see that these samples mainly distribute in northeast China, north China, the central and western regions and the southern coastal areas.



Fig. 1. Geographical distribution of the sample

In this paper, the type of the buildings contains a wide range, as shown in Figure 2. The proportion of residential buildings and schools are more, and other types of buildings are less. The ventilation and heating ways of these buildings are shown in Figure 3. For rural areas, the majority of rural buildings use natural ventilation in summer and self-heating in winter. Urban buildings mostly use natural ventilation combined with mechanical ventilation, and mostly use central heating in winter, use natural ventilation in transition season. As for schools and other places, they mostly use natural ventilation in summer and central heating in winter. Shopping malls, subways, railway stations and other public buildings, mostly adopt mechanical ventilation and central heating.

In this paper, the majority of people's activities is sedentary or mild activity, more than 80% of the literature set the human metabolic rate between 1.0met and 1.3met, most of the research set the data to 1.2met.

In different literatures, there are some differences in indoor temperature and humidity. There are a great relationship between the indoor temperature and the building's cooling or heating way. People's living habits also related to the indoor temperature, so the data is irregular. Most of the data is within the scope of human thermal comfort, but in several buildings people feel uncomfortable at the current temperature of the room.

The distribution of indoor humidity and wind speed is more discrete. In general, the humidity in winter is much smaller than it in summer. The wind speed in summer is generally higher than it in winter, which is due to the need for keeping warm in winter.



Fig. 3. Sample distribution of ventilation mode and heating mode

3. Results

3.1. Thermal comfort temperature contrast

Table 1 and table 2 shows the thermal comfort temperature range in different cities.

Thermal comfort range is according to 80% or 90% satisfaction rate of the PMV evaluation index ^[3], PMV index is almost the same in the current study, the climate zone and heating mode is the main difference.

Table 1. Temperature range	of thermal	comfort in	transition	seasor
----------------------------	------------	------------	------------	--------

City	Comfort temperature range ($^\circ\!\mathbb{C}$)	City	Comfort temperature range (${}^\circ\!\!\mathbb{C}$)
	Urban housing	Harbing ^[70]	21~24.5
Harbing ^[35]	18.7~25.9	Beijing ^[39]	20.8~26.3
Xian ^[36]	≥14.5	Beijing ^[39]	20.7~26.3
Xian ^[37]	\geq 11.4,neutral21.3	Xian ^[71]	neutral :17.1
Xian ^[38]	neutral:20.76	Xian ^[71]	neutral :20.1
	Public building	Changsha ^[72]	15.1~22.4
Harbing ^[69]	21~27	Shenyang ^[73]	15.5~22.4

In table1, the transition season building all adopts natural ventilation (except Guangdong). The specific range of thermal comfort is related to the body's clothing, lifestyle and local climate. The thermal comfort temperature distribution in the same climate zone in the transition season is also the same, which can provide a reference for architectural design.

In table 2, rural people have a stronger ability to resist cold and they have a wider range of thermal comfort than city people in winter. The reason is that most of rural regions have no air-conditioning and central heating, and a majority of people engaged in manual labor. Although the weather is cold in the north, the thermal comfort temperature is not lower than that in the south because of the central heating. Most of crowded public buildings adopt the mechanical ventilation and centralized heating, this is because that people with big traffic need more fresh air, and mechanical ventilation can ensure the need of the fresh air. Mechanical ventilation can maintain the temperature in a stable range, therefore, people's thermal comfort range generally narrower.

summer		winter			
City	Comfort temperature range (${}^\circ\!\!{}^\circ\!\!{}^\circ$)	City Comfort temperature range (°C)			
Rural residential in summer		Rural residential in winter			
Xian ^[4]	20.7~29.5	Harbing ^[10]	15~18		
Hanzhong ^[5]	22.6~26.6	Haerbing ^[11]	≥8.8,neutral 14.4		
Jiangzhe ^[6]	≤30	Harbing ^[12]	4.4~21.3		
Liuyang ^[7]	21.8~31.6	Yanbian ^[13]	15~17		
Xiangbei ^[8]	15.65~30.14	Yingchuan ^[14]	≥16		
Yuedong ^[9]	23.8~29.0	Xian ^[4]	9.0~15.8		
City	residential in summer	Guanzhong ^[15]	neutral 12.7		
Haerbing ^[17]	21.5~31.0	Guanzhong ^[15]	≥ 8		
Jiaozuo ^[18]	20.7~29.2	Beijing ^[16]	≥10.9,neutral 18.4		
Baotou ^[19]	23.8~26.9	Xiangbei ^[8]	8.4 ~ 15.65		
Yingchuan ^[20]	≤28.5	C	ity residential in winter		
Xian ^[4]	26.0~30.7	Harbing ^[27]	18.0~25.5		
Beijing ^[21]	≤30	Harbing ^[28]	18.5~26.5		
Chongqing ^[22]	22.6~30.5	Harbing ^[12]	19.3~28.6		
	22.5~28.7	Harbing ^[29]	neutral 22.9		
Jiangzhe ^[6]	≤30	Xian ^[4]	9.0~15.8		
Changsha .etc [23]	25.1~30.3	Jiaozuo ^[30]	11.6~24.2		
Changsha .etc ^[23]	25.0~31.6	Nanyang ^[31]	11.2~16.8		
Kunming ^[24]	20.8~25.1	Hangzhou ^[32]	12.6~18.6		
Nanning ^[25]	25.8~28.9	Chengdu .etc ^{[33}	14.35~16.53		
Shenzhen ^[26]	≤29.5	Hefei ^[32]	13.22~23.22		
public	architecture in summer	Shanghai ^[34]	≥14.6		
Beijing ^[39]	neutral 26.9	public architecture in winter			
Beijing ^[40]	neutral 25.7	Harbing ^[57]	19.6~24.4		
Beijing ^[41]	24.1~29.7	Harbing ^[58]	21~24.5		
Shanghai ^[42]	neutral 23.61	Guanzhong ^[59]	12.7~16.9		
Chongqing ^[43]	25.5~29.8	Beijing ^[39]	19.9~25.8		
Chongqing ^[44]	24.8~28.3	Beijing ^[40]	17.6~24.6		
Haikou ^[45]	23.34 ~ 27.82	Beijing ^[41]	neutral 21.8		
Nanning ^[46]	25.8~28.9	Lanzhou ^[60]	18.2~22.2		
Nanning ^[47]	17.8~24.8	Shanghai ^[42]	neutral 16.60		
Xian ^[48]	24.45~30.6	Chongqing ^[61]	14.04~24.2		
Jiayuguan ^[49]	24.9~29.5	Chongqing ^[44]	17.5~23.0		
Shanghai ^[50]	≤23.2	Wuhan ^[62]	neutral 21.7		
Chengdu ^[51]	24.25~30.5	Xiamen ^[63]	15.6~16.0		
Xian ^[52]	22.0~27.8	Harbing ^[64]	10~16.4		
Changsha ^[53]	25.5~29.4	Shengyang ^[65]	16.6~21.3		
Changsha ^[54]	22.6~26.5	Beijing ^[64]	10~20.5		
Guangzhou ^[55]	21.6~29.3	Lanzhou ^[66]	13~17		
Guangzhou ^[56]	23~27	Xian ^[67]	13.8~23.8		
		Xian ^[68]	14.3~23.3		
		Nanjing ^[64]	10~22.3		
		Guangzhou ^[64]	15.8~25.2		

Table 2. Temperature range of thermal comfort

3.2. Calculation and analysis of thermal neutral temperature

The thermal neutral temperature and the measured temperature data of all the samples were collected and analyzed, as shown in figure 4. In order to verify that the average temperature to be considered as ideal thermal comfort temperature is reliable, we get the deviation and variation coefficient to indicate the degree of discrete data. The variation coefficient is the ratio of the standard deviation of the mean. When the variation coefficient is less than 15%, the data is reliable. The calculation of the dispersion degree about using the average neutral temperature as the thermal neutral temperature is shown in table 3.



Fig. 4. Measured temperature and thermal comfort temperature distribution

Figure 4 shows that the measured temperature nearly has no effect on the thermal comfort temperature in summer, and the average value of the thermal neutral temperature is 25.7° C.

In transition season, buildings mostly use natural ventilation and the average of thermal neutral temperature is 20.8 °C. During the transition period, with the increase of the measured room temperature, the thermal neutral temperature is on the rise (except for small part of the data). It shows that the measured room temperature can affect the thermal neutral temperature.

Tal	ble (3. Ca	lculation	of	the	dispersion	degree
-----	-------	-------	-----------	----	-----	------------	--------

Season	Summer	Transition	Winter(village)	Winter(city)
The average neutral temperature ($^{\circ}$ C)	25.7	20.8	15.4	20.0
Mean absolute deviation(°C)	1.416	1.648	2.210	2.064
Standard deviation (°C)	1.893	2.034	2.660	2.590
Variation coefficient (%)	7.37	9.77	17.26	12.98

The average of urban thermal neutral temperature in winter is about 20.0 °C. With the increase of the measured

temperature, the thermal neutral temperature is on the rise. The distribution range of thermal comfort temperature is wide, which is related to the location of the building and the ways of heating, lifestyle, etc. In winter, because there is no central heating in the south, the mean thermal neutral temperature in the south and north will be calculated respectively. The average temperature is 18.6 °C in the south and 20.3 °C in the north. Due to the lack of central heating in winter in the south, the thermal adaptability of human body is strong, the average of the thermal neutral temperature in the south is lower than that in the north.

The average of thermal neutral temperature is 15.4° C in rural winter, which is significantly lower than that in the city building. The distribution range of thermal comfort temperature is wide, which is because most of rural buildings have no central heating and people have a stronger cold tolerance. The thermal neutral temperature is between 11.6° C- 18.4° C.

4. Conclusions

The research systematically summed up investigations on thermal comfort in China, including natural ventilation and mechanical ventilation; Human body is basically in a meditation state. Most indoor temperature of the building meet the human thermal comfort needs, but there are also a part of the buildings does not meet the human thermal comfort. The indoor wind speed is small, the humidity distribution scope is broad from 19% to 87%. Most of the literature is based on PMV, and thermal comfort satisfaction rate range is 80% to 90% of the PMV evaluation index by the actual investigation. The following conclusions are drawn.

- The results show that different geographical location can affect human thermal adaptation. In Shanxi, Guangdong, Beijing and other research areas with many samples, they have greater reference value. In addition, for buildings using natural ventilation, we should take the human body's thermal adaptability into account, and it will have a wider thermal comfort range.
- The thermal comfort temperature is not completely related to the climate zone, which also can be affected by the actual insulation measures and the way of cooling and heating.
- The average neutral temperature are summarized as follows: the summer: 25.7°C; winter city construction: 20.0°C (South: 18.6°C, North: 20.3°C); winter rural construction: 15.4°C; transition season: 20.8°C.
- The results show that the thermal comfort temperature will increase with the increase of the measured room temperature, that is to say, the long-term living environment can affect human thermal adaptation. Indoor temperature can affect the human's thermal comfort range, which is particularly evident in winter.

Acknowledgements

Before finish this paper, please allow me to express my most sincere thanks to the research workers who have helped me in my work. The work is supported by a grant from the National 13th Five Year Plan of national key reasearch projects "The net zero energy building technology system and key technology development" (2017YFC07 02600). I am thankful to its' support. I would like to extend my sincere gratitude to the 2017 IEA-EBC project from where I learned a lot. I am also deeply grateful to the other partners who give me many good suggestions and support.

References

- [1] Zhaojun Wang, Zhiqiang Zhang, Leming Lian. Discussion of thermal comfort indices and design indoor temperature for winter heating. J.HVAC,2002,32(2):26-28.
- [2] Mao Yan. Study on Climate Adaptability of human beings to thermal comfort in China. D. Xian: Xian University Of Architecture And Technology, 2006.
- [3] Haiying Wang, Songtao Hu. Analysis on the Applicability of PMV Thermal Comfort Model.J. Building Science, 2009, 25(6):108-114.
- [4] Qian Yang. Study on the Indoor Thermal Comfort in the Cold Zone. D. Xian: Xian University Of Architecture And Technology, 2006.
- [5] Menglin Zou, Liu Yang, Haiyan Yan.Investigation of summer thermal comfort in rural housing in Hanzhoung. J. Sichuan Institute of Building Science, 2013, 39(2):341-345.
- [6] Xiuling Ji, Baoguo Wang, Shuyan Liu, Zizhu Dai. Study on Thermal comfort in Non-Air-conditioned Buildings in Jiangsu and Zhejiang provinces. J. Journal of Beijing Institute of Technology, 2004,24(12):1100-1103.

- [7] Xiangbei long-term thermal environment evaluation index of rural residential. D. Hunan: Hunan University, 2010.
- [8] Jie Han, Guoqiang Zhang, Jin Zhou. Research on the Rural Residential Thermal Environment and Thermal Comfort in Hot Summer and Cold Winter Climate Zone. J. Journal of Hunan University (NATURAL SCIENCE EDITION), 2009,06:13-17.
- [9] Ling Jin, Qinglin Meng, Lihua Zhao, Yufeng Zhang, Lin Chen. Indoor Environment and thermal comfort in rural houses in east Guangdong of China. J. Architectural and environmental engineering, 2013, 02:105-112.
- [10] Hong Jin, Hua Zhao, Xiuping Wang. Research on the Indoor Thermal Comfort Environment of Rural Housing in Winter in Super-cold Region.J. Journal of Harbin Institute of Technology.2006,38(12):2108-2111.
- [11] Zhaojun Wang, Xiaohui Sheng, Yuchen Ji. Field Survey on Indoor Thermal Comfort in Rural Houses Around Harbin in Winter.J.HVAC, 2014,44(12):71-75.
- [12] Xiaohui Sheng. Field Test and Analysis of Thermal Comfort at Rural Houses and Urban Residential Buildings in Severe Cold Region. D. Harbin: Harbin Institute of Technology. Harbin: Harbin Institute of Technology.
- [13] Hong Jin, Xiuping Wang, Hua Zhao. Yanbian Korean rural residential indoor thermal comfort temperature. The Eleventh National Symposium on Building Technology, C. Nanjing, 2006.
- [14] Yiyun Zhu, Jiaping Liu. Research on the indoor thermal environment of rural architecture in winter in north western areas. 2010 China (Beijing) International Conference on building technology, C, Beijing
- [15] Liu Yang, Qian Yang, Haiyan Yan, Jiaping Liu. Field study on thermal comfort of rural houses in winter in the Guanzhong region, Shaanxi Province, J. Journal of Xi'an University Of Architecture And Technology, 2011,43(4):551-556.
- [16] Li Huang, Yinxin Zhu, Qin Ouyang, Bing Cao. Indoor thermal comfort in rural houses around Beijing in heating season. J.HVAC,2011,41(6):83-115.
- [17] Lin Zhang.Study on Adaptation and Thermal Comfort of Residents in Harbin.D.Harbin: Harbin Institute of Technology, 2010.
- [18] Haiyan Yan, Liu Yang. Field Study on Occupant Thermal Comfort in Residential Buildings of Jiaozuo City in Summer.J.HVAC,2012,42(4):96-103.
- [19] Liu Yang, Zhiwei Lian, Zhaoxia Zhou. Experimental study on chloride penetration into concrete after carbonation under wet and dry cycle mechanism, J. Journal of Xi'an University Of Architecture And Technology,2012,44(3):369-375.
- [20] Haiyan Yan, Liping Hao, Liu Yang, Daoyi Li. Indoor Environment and Thermal Comfort of Residential Buildings in Yinchuan in Summer, J. Building Science, 2015, 31(12):20-27.
- [21] Yizai Xia, Rongyi Zhao, Yi Jiang. Thermal comfort in naturally Ventilated houses in Beijing, J.HVAC, 1999, 29(2):1-5.
- [22] Heng Zhang. Thermal Comfort of Olderly People During Summer in Residential Buildings, D. Chongqing University, 2013.
- [23] Wei Yang. The Investigation of Thermal Comfort and Thermal Adaptation in Residential Buildings during the Summer Season of Hot Summer/Cold Winter Region. D.Hunan University,2007.
- [24] Wei Wang, Huilong Luo, Yafeng Gao, Baizhan Li, Yongqiao Wang. Residential building Thermal Environment Test and Thermal Comfort Investigation in Kuming Area in Summer. J.HVAC, 2011, 41(6):93-95.
- [25] Lixing zheng, Wei Lu, Hongjie Chen. An Analysis of Indoor Thermal Comfort and Air Conditioning Energy Consumption in Summer Nanning, J. Cryogenic Building technology, 2011,10:110-112.
- [26] Jiaolin Wang. Study on thermal comfort of high-rise residential environment in Shenzhen, J. China housing facilities, 2009,04:37-39.
- [27] Zhaojun Wang, Zhiqiang Zhang, Leming Lian. Field Experiments on Occupant Thermal Comfort in Harbin, J. Journal of Harbin Institute of Technology, 2002, 34(4):500-504.
- [28] Lin Zhang, Zhaojun Wang, Jianing Zhao, Yanan He.Study on thermal comfort of residents before and after heating period in Harbin. Proceedings of National Conference on HVAC refrigeration in 2010 ,C. Hangzhou 2010.
- [29] Jing Ren. Field Study on Human Thermal Adaptation at Residential and Office Buildings in Severe Cold Area, D.Harbin: Harbin Institute of Technology.2014.
- [30] Haiyan Yan, Liu Yang, Shubing Zhou, Menglin Zou, Lu Gao. Field Study on Occupant Thermal Comfort in Residential Building in Jiaozuo City in Winter, J.HVAC, 2009, 41(11):119-125.
- [31] Junge Li. An Adaptive Thermal Comfort Model for Hot Summer and Cold Winter Context, D. Xian: Xian University Of Architecture And Technology, 2012.
- [32] Yaya Li. The indoor thermal environment in winter of the residential for the hot summer and cold winter context—take Hangzhou、Hefei for example ,D. Xian: Xian University Of Architecture And Technology, 2012.
- [33] Hongliu Shi, Zhiwei Wang, Zengfeng Yan. Indoor design temperature research for heating in hot summer and cold winter zone, J.Xian Building Science Research, 2015, 41(4):123-131.
- [34] Tian Wang, Hang Yu, Yu Jiao, Yusong An, Yifan Yu. Indoor Environment Investigation and Evaluation of Elderly Care Centers in Shanghai, J. Building Science, 2015,04:45-49.
- [35] Jian Wang, Shugang Wang. Field Study on Thermal Comfort in Dormitories of a University in Harbin, J.HVAC, 2013, 43(10):96-99.
- [36] Mingzhi Luo, Baizhan Li, Xiaolin Xu. Field Survey and Analysis on Students' Thermal Comfort in Dormitories in Xian in Transition Season, J. Building Science, 2013, 29(4):25-30.
- [37] Wanying Qu, Haiyan Yan, Liu Yang, Wuxing Zheng. Study on Climate Adaptation Model for Human Thermal Comfort in Xian in TransitionSeasons, J. Building Science, 2014,30(2):51-56.
- [38] Lujian Bai, Bing Song, Liu Yang. Field Study on Occupant Thermal Comfort of Residential Buildings in Xian in Spring, J.Building Energy Efficiency, 2014,42(285):68-71.
- [39] Min Li, Bing Cao, Qin Ouyang, Yinxin Zhu. Long-time investigation on indoor thermal comfort in campus buildings in Beijing, J.HVAC, 2014,44(12):67-70.
- [40] Bing Cao. Research on the Impacts of Climate and Built Environment on Human Thermal Adaptation, D.Beijing: Tsinghua University, 2012.

- [41] Bing Cao, Yinxin Zhu, Qin Ouyang, Li Huang. Field study of incloor thermal comfort in campus buildings in Beijing during summer and winter, J.HVAC, 2012, 42(5):84-89.
- [42] Jinmei Feng, Zhiwei Lian, Yongjie Yuan. Research on Thermal Comfort of Classroom in Shanghai in Winter and Summer, C. Shanghai, 2007.
- [43] Mingzhi Luo, Baizhan Li, Xiaolin Xu. Research on Classroom Thermal Environment during the Summer in Chongqing, J. Journal of Chongqing University of architecture, 2005, 27(1):88-91.
- [44] Jin Liu. Study on the Indoor Thermal Environment and Human Thermal Comfort In Natural Ventilation Building in Summer-Hot and Winter-cold Zone, D.Guangxi University, 2011.
- [45] Zhuangqin Yin, Chunjing Shang, Yanrong Liu, Kun Song, Jin Cai. Thermal Comfort in Naturally Ventilated Buildings in Hot Humid Area in Summer—Take Haikou for Example J. Building Science, 2015,08:176-182.
- [46] Lixing Zheng, Wei Lu, Hongjie Chen. An Analysis of Indoor Thermal Comfort and Air Conditioning Energy Consumption in Summer Nanning. Cryogenic Architecture technology, J. 2011,(10): 110-112.
- [47] Qian Ma. The Thermal Comfort Research of Campus Architecture in Hot Summer and Warm Winter Zone, D.Guangxi University, 2011.
- [48] Zilong Xu, Yuhui Di, Chunyang Jiang, Ying Liu. A Thermal Comfort Field Survey in Railway Station Waiting Room in Summer, J.Refrigeration, 2014, 33(1):28-32.
- [49] Yingying Xie.Summer Thermal Environment Research in Jiayuguan Railway Station, D.Chengdu: Southwest Jiaotong University, 2009.
- [50] Chunxiao Jiang, Xiaojiang Ye, Zhiwei Lian. Investigation on Thermal Comfort in Shanghai Metro System and it's Improvement, J. Ergonomics, 2007, 13(1):14-16.
- [51] Qian Lan. Thermal Comfort Research of Waiting Room in Chengdu Railway Station., D. Chengdu: Southwest Traffic University, 2009.
- [52] Tao Yuan, Jiandong Li, Zhichao Wang. Investigation and analysis of thermal environment of public buildings in Xian, J.Railway Standard Design, 2010, S2.
- [53] Jiandong Li, Zhichao Wang, Tao Yuan. Study on indoor thermal and moisture environment of Changsha office building, J. Building Science, 2010,26(10):114-117.
- [54] Tao Yuan, Jiandong Li, Zhichao Wang, Changzhi Yang. Study on Heat and Moisture Status and Thermal Comfort in Public Buildings of Changsha, J. Building Science, 2010,26(4):38-47.
- [55] Jiandong Li, Zhichao Wang, Yingxia Yang. Field study of thermal comfort in public building of Guang-zhou in air-conditioning season, Proceedings of the fifth annual meeting of the indoor environment and health branch of the Chinese Society for Environmental Sciences.
- [56] Qinhua Hu, Xiujuan Ding, Kuishan Li, Qinghong Zheng. Research on human Thermal Comfort for Warm-wet Climate Zones in South China, J.HVAC, 2008,08:17-21.
- [57] Hongye He. Study on the Indoor Thermal Environment of Universityin Harbin, D. Harbin Engineering University, 2007.
- [58] Aixue Li. Study on Thermal Comfort and Thermal Adaptation in University Buildings in Severe Cold Region., D.Harbin: Harbin Institute of Technology.2007.
- [59] Dengjia Wang, Hanxu Wang, Yanfeng Liu, Jiaping Liu. Field study on thermal comfort of township and villages primary and secondary classrooms in winter in Guanzhong region, Shaanxi province, J. Journal of Xi'an University Of Architecture And Technology (NATURAL SCIENCE EDITION), 2016,48 (2): 277-281.
- [60] Yong Guan, Chao Chen. An investigation on the thermal environment of college classrooms in Lanzhou in winter, J. Environment and healthy, 2010, 02:159-160.
- [61] Baizhan Li, Jing Liu, Runming Yao. Investigation and analysis on Classroom thermalenvironment winter in Chongqing,J.HVAC,2007,37(5):115-117.
- [62] Xiaojiang Ye, Huanxin Chen, Zhaoxia Zhou, Xianchun He, Zhiwei Lian. Thermal Environmental Quality Study of University Classrooms in Winter in Wuhan, J. Building Energy & Environment, 2009, 28(1):72-74.
- [63] Qiuhua Tao, Li Li. Thermal environment measurement and thermal comfort prediction for university classrooms in Xiamen in winter, J.HVAC, 2012, 42(4):72-75.
- [64] Yong Jiang, Yinxin Zhu. Design Temperature of Underground Stations in Winter, J. HVAC. 2002, 32(4):20-22.
- [65] Runping Niu, Pinghong Zhang, Qizheng Chen. Indoor thermal comfort and optimization of design parameters in winter in Shenyang, J. Building Energy & Environment, 2007, 13(4):45-47.
- [66] Feng Xu. Studying for Cold and Arld Regions on Thermal Comfort Temperature and Saving Energy of the Supermarkets Building,J. Building Energy & Environment, Building Energy & Environment, 2007,13(4):45-47.
- [67] Tao Yuan, Jiandong Li, Zhichao Wang, Yun Liu, Yingxia Yang. Study of Thermal Environment in Office and Market Buildings of Xian in Winter, J. Refrigeration and air conditioning and power machinery, 2010,05:70-73.
- [68] Haiying Wang, Songtao Hu. Field study on indoor therma l comfort of shopping mal ls in hot summer and warm winter zone, J.HVAC,2015,45(6):76-81
- [69] Jian Wang, Zhaojun Wang. Field Studies on University Classroom's Thermal Comfort in Harbin, J.HVAC, 1999, 29(2):1-5.
- [70] Lujian Bai, Liu Yang, Shuting Li, Bing Song. Study on the thermal environment of middle and primary school classrooms in spring in Xian,J.Journal of Xi'an University Of Architecture And Technology (NATURAL SCIENCE EDITION),2015,47(3):407-412.
- [71] Wei Yang, Guoqiang Zhang. Thermal Comfort Investigation of Buildings a Campus in Hunan.J.HVAC,2006,36(9):95-101.
- [72] Tao Yuan, Jiandong Li, Zhichao Wang, Zhaowei Xu. Study of thermal environment in public buildings of different climatic regions during transition season.J. Sichuan architectural science research, 2010,36 (5):249-261.
- [73] Guozhi Qiu. Assessment of Air Environmental and Research of Control Strategy for Ventilation and Air-conditioning in Office Buildings.D. Xian: Xian University Of Architecture And Technology, 2012.